



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room Ka

Test / COC #: 1101756
Sample ID: 1101756-1

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; ND = Analyte not detected at or above the detection limit;
NR = Not reported; dry = Sample results reported on a dry weight basis.
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room Kb

Test / COC #: 1101756
Sample ID: 1101756-2

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room Kc

Test / COC #: 1101756
Sample ID: 1101756-3

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 1

Test / COC #: 1101756
Sample ID: 1101756-4

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 2

Test / COC #: 1101756
Sample ID: 1101756-5

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 3

Test / COC #: 1101756
Sample ID: 1101756-6

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit;
 NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 4

Test / COC #: 1101756
Sample ID: 1101756-7

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 5

Test / COC #: 1101756
Sample ID: 1101756-8

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit;
 NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 6

Test / COC #: 1101756
Sample ID: 1101756-9

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 7

Test / COC #: 1101756
Sample ID: 1101756-10

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 8

Test / COC #: 1101756
Sample ID: 1101756-11

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 9

Test / COC #: 1101756
Sample ID: 1101756-12

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 10

Test / COC #: 1101756
Sample ID: 1101756-13

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 11

Test / COC #: 1101756
Sample ID: 1101756-14

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 12

Test / COC #: 1101756
Sample ID: 1101756-15

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 13

Test / COC #: 1101756
Sample ID: 1101756-16

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 14

Test / COC #: 1101756
Sample ID: 1101756-17

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit;
 NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 15

Test / COC #: 1101756
Sample ID: 1101756-18

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room16

Test / COC #: 1101756
Sample ID: 1101756-19

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit;
 NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 17

Test / COC #: 1101756
Sample ID: 1101756-20

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit;
 NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Drinknig Fountain Outside Rm 17

Test / COC #: 1101756
Sample ID: 1101756-21

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 18

Test / COC #: 1101756
Sample ID: 1101756-22

CERTIFICATE OF WATER ANALYSIS

Table with 4 columns: TEST ITEM, RESULT, ACCEPTABLE RANGE, DETERMINATION. Row 1: LEAD, ND ppb, 0 to 15 ppb, Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; uS/cm = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; ND = Analyte not detected at or above the detection limit;
NR = Not reported; dry = Sample results reported on a dry weight basis.
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: http://water.epa.gov/drink/contaminants/index.cfm

Handwritten signature of Carlos Ochoa

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Drinking Fountain Outside Rm 18

Test / COC #: 1101756
Sample ID: 1101756-23

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 19a

Test / COC #: 1101756
Sample ID: 1101756-24

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 20b

Test / COC #: 1101756
Sample ID: 1101756-25

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 22

Test / COC #: 1101756
Sample ID: 1101756-26

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit;
 NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 23

Test / COC #: 1101756
Sample ID: 1101756-27

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 24

Test / COC #: 1101756
Sample ID: 1101756-28

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 25

Test / COC #: 1101756
Sample ID: 1101756-29

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit;
 NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 26

Test / COC #: 1101756
Sample ID: 1101756-30

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit;
 NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Drinknig Fountain Outside Kinder Class

Test / COC #: 1101756
Sample ID: 1101756-31

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Room 28

Test / COC #: 1101756
Sample ID: 1101756-32

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Teacher Break Room

Test / COC #: 1101756
Sample ID: 1101756-33

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Drinknig Fountain Outside Boys Bathroom

Test / COC #: 1101756
Sample ID: 1101756-34

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit;
 NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Kitchen

Test / COC #: 1101756
Sample ID: 1101756-35

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	7.8 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Nurse Office

Test / COC #: 1101756
Sample ID: 1101756-36

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit;
NR = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

ISLA VISTA
6875 EL COLEGIO RD
, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: January 4, 2018
Date Received: January 11, 2018
Analysis Date: January 16, 2018
Report Date: January 16, 2018
Sample Location: Library

Test / COC #: 1101756
Sample ID: 1101756-37

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit;
 NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager