



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room Ka

Test / COC #: 1091557
Sample ID: 1091557-1

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	1.9 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room Kb

Test / COC #: 1091557
Sample ID: 1091557-2

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	1.7 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room1

Test / COC #: 1091557
Sample ID: 1091557-3

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	1.9 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room2

Test / COC #: 1091557
Sample ID: 1091557-4

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room3

Test / COC #: 1091557
Sample ID: 1091557-5

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	1.8 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room4

Test / COC #: 1091557
Sample ID: 1091557-6

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	2.1 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room5

Test / COC #: 1091557
Sample ID: 1091557-7

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>



 Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room6

Test / COC #: 1091557
Sample ID: 1091557-8

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room7

Test / COC #: 1091557
Sample ID: 1091557-9

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	2.2 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room8

Test / COC #: 1091557
Sample ID: 1091557-10

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	1.7 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room9

Test / COC #: 1091557
Sample ID: 1091557-11

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	1.8 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>



 Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room 10

Test / COC #: 1091557
Sample ID: 1091557-12

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room 11

Test / COC #: 1091557
Sample ID: 1091557-13

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	2.9 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room 12

Test / COC #: 1091557
Sample ID: 1091557-14

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	2.2 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room 13

Test / COC #: 1091557
Sample ID: 1091557-15

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	3.5 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>



 Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room 14

Test / COC #: 1091557
Sample ID: 1091557-16

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	2.4 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room 15

Test / COC #: 1091557
Sample ID: 1091557-17

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	1.9 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room 16

Test / COC #: 1091557
Sample ID: 1091557-18

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	2.1 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room 18

Test / COC #: 1091557
Sample ID: 1091557-19

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>



Carlos Ochoa, Quality Control Manager



GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room 19

Test / COC #: 1091557
Sample ID: 1091557-20

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room 20

Test / COC #: 1091557
Sample ID: 1091557-21

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room 21

Test / COC #: 1091557
Sample ID: 1091557-22

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>



 Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room 24

Test / COC #: 1091557
Sample ID: 1091557-23

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	2.6 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>



Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room 25

Test / COC #: 1091557
Sample ID: 1091557-24

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	2.3 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Room 26

Test / COC #: 1091557
Sample ID: 1091557-25

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	6.1 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: #c-counseling Room

Test / COC #: 1091557
Sample ID: 1091557-26

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	3.3 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Computer Lab

Test / COC #: 1091557
Sample ID: 1091557-27

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	33.1 ppb	0 to 15 ppb	*** FAIL ***

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: * FAIL *****

Some or all of the tested parameters do not meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels (MCLs) for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Mpr

Test / COC #: 1091557
Sample ID: 1091557-28

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Kitchen

Test / COC #: 1091557
Sample ID: 1091557-29

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	3.1 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Mpr Teacher's Workroom

Test / COC #: 1091557
Sample ID: 1091557-30

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	13.1 ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Workroom

Test / COC #: 1091557
Sample ID: 1091557-31

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; **cfu** = colony forming units; **mg/L** = milligrams per liter; **ntu** = nephelometric turbidity units
pH = acidity/alkalinity units; **ppm** = parts per million; **ppb** = parts per billion; **µS/cm** = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; **ND** = Analyte not detected at or above the detection limit; **NR** = Not reported; **dry** = Sample results reported on a dry weight basis.
RPT = Relative percent difference; **V** = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Outside Lunch Fountain

Test / COC #: 1091557
Sample ID: 1091557-32

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

Test Address:

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Lower Grade Fountain

Test / COC #: 1091557
Sample ID: 1091557-33

CERTIFICATE OF WATER ANALYSIS

TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
LEAD	ND ppb	0 to 15 ppb	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; µS/cm = microSiemens per centimeter
 U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
 DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
 RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
 I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
 Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>

Carlos Ochoa, Quality Control Manager



1675 North Commerce Parkway, Weston, FL 33326 (954) 384-4446

Test Address:

GOLETA UNION SCHOOL DISTRICT
5669 HOLLISTER AVE
GOLETA, CA 93117

LA PATERA
555 NORTH LA PATERA LN
GOLETA, CA 93117

Email: nalvarado@goleta.k12.ca.us
Phone: (805) 681-1200

Sample Date: November 17, 2017
Date Received: November 24, 2017
Analysis Date: November 29, 2017
Report Date: November 29, 2017
Sample Location: Upper Grade Fountain

Test / COC #: 1091557
Sample ID: 1091557-34

CERTIFICATE OF WATER ANALYSIS

Table with 4 columns: TEST ITEM, RESULT, ACCEPTABLE RANGE, DETERMINATION. Row 1: LEAD, 2.3 ppb, 0 to 15 ppb, Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; uS/cm = microSiemens per centimeter
U = Indicates that the compound was analyzed for but not detected. The value associated with the qualifier shall be the laboratory method detection limit.
DET = Analyte detected; ND = Analyte not detected at or above the detection limit; NR = Not reported; dry = Sample results reported on a dry weight basis.
RPT = Relative percent difference; V = Indicates that the analyte was detected in both the sample and the associated method blank.
I = The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
Z = too many colonies were present for accurate counting

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: http://water.epa.gov/drink/contaminants/index.cfm

Handwritten signature of Carlos Ochoa
Carlos Ochoa, Quality Control Manager